

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150619 – E226322  
**Report Reference** E226322 - 20090929  
**Issue Date** 2015-JUNE-19

**Issued to:** INGRAM PRODUCTS INC  
1376 Enterprise Pkwy  
Ashland, OH 44805-8926 USA

**This is to certify that representative samples of** Industrial Control Panels  
USL, CNL Enclosures for Industrial Control Panels, Type  
Rated 1, 2, 3, 3R, 4, 4X, 5, 6, 6P, 12 and 13  
(See following page for additional information.)

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508, "Industrial Control Equipment."  
CSA-C22.2 No. 14, "Industrial Control Equipment."

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product t.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150619 – E226322  
**Report Reference** E226322 - 20090929  
**Issue Date** 2015-JUNE-19


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Additional Information

### **Environmental ratings -**

- I. Enclosures with 2 screws and a hinge is rated type 1, 2, 3, 3R, 4, 4X, 5, 12 and 13.
- II. Enclosures with 2 latches and a hinge is rated type 1, 2, 3, 3R, 4, 4X, 5, 12 and 13.
- III. Enclosures with 4 screws and a cover are rated type 1, 2, 3, 3R, 4, 4X, 5, 12 and 13.
- IV. Enclosures with 4 screws and a hinge or 4 screws and a cover are rated type 6P
- V. Enclosures with 1 latch and a hinge is rated type 1, 2, 3, 3R, 4, 4X, 5, 12 and 13.

Ambient Temperature - 70° C.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

